

Location	Lab ID	Results	Location	Lab ID	Results
52 Samples:					
Rm 9 Water Fount.	JFKG2	0.0082	Rm 2 Bathroom Sink	JFKG28	0.0120
Rm 9 Sink	JFKG3	0.0048	Rm 1 Sink	JFKG29	0.0091
Rm 9 Bathroom Sink	JFKG4	0.0065	Rm 1 Water Fount.	JFKG30	0.0044
Rm 10 Water Fount.	JFKG5	0.0061	Rm 1 Bathroom Sink	JFKG31	0.0049
Rm 10 Sink	JFKG6	0.0075	Rm 65 Sink	JFKG32	0.0024
Rm 10 Bathroom Sink	JFKG7	0.0142	Rm 65 Water Fount	JFKG33	0.0014
Rm 8 Water Fount.	JFKG8	0.0035	Rm 62 Sink	JFKG34	0.0016
Rm 8 Sink	JFKG9	0.0019	Rm 62 Water Fount	JFKG35	0.0022
Rm 8 Bathroom Sink	JFKG10	0.0057	Rm 63 Sink	JFKG36	0.0020
Rm 7 Sink	JFKG11	0.0064	Rm 63 Water Fount	JFKG37	0.0008
Rm 7 Water Fount.	JFKG12	0.0030	Rm 60 Sink	JFKG38	0.0009
Rm 7 Bathroom Sink	JFKG13	0.0044	Rm 60 Water Fount	JFKG39	0.0006
Rm 6 Sink	JFKG14	0.0066	Rm 61 Sink	JFKG40	0.0014
Rm 6 Water Fount.	JFKG15	0.0073	Rm 61 Water Fount	JFKG41	0.0009
Rm 6 Bathroom Sink	JFKG16	0.0065	Rm 58 Sink	JFKG46	0.0017
Rm 5 Water Fount.	JFKG17	0.0081	Rm 58 Water Fount	JFKG47	0.0012
Rm 5 Sink	JFKG18	0.0048	Rm 50 Sink	JFKG48	0.0022
Rm 5 Bathroom Sink	JFKG19	0.0096	Rm 50 Lft Sink	JFKG49	0.0009
Rm 4 Water Fount.	JFKG20	0.0062	Rm 50 Rt Sink	JFKG50	0.0009
Rm 4 Sink	JFKG21	0.0030	Rm 54 Rt Sink	JFKG51	<0.0005
Rm 4 Bathroom Sink	JFKG22	0.0059	RM 54 Lft Sink	JFKG52	0.0011
Rm 3 Sink	JFKG23	0.0041	Bottle Filler	JFKG53	<0.0005
Rm 3 Water Fount.	JFKG24	0.0031	Water Fount.	JFKG54	<0.0005
Rm 3 Bathroom Sink	JFKG25	0.0118	Rm 55 Rt Sink	JFKG55	0.0006
Rm 2 Water Fount.	JFKG26	0.0020	Rm 55 Middle Sink	JFKG56	<0.0005
Rm 2 Sink	JFKG27	0.0038	Rm 55 Lft Sink	JFKG57	<0.0005

***Break in Numbers

Location	Lab ID	Results (mg/l)	Location	Lab ID	Results
Rm 29 Sink	JFKG58	0.0005	Lft Water Fount	JFKG42	<0.0005
Bottle Filler	JFKG59	<0.0005	Bottle Filler	JFKG43	<0.0005
Water Fount.	JFKG60	<0.0005	Left Sink	JFKG44	<0.0005
Boys Lft Sink	JFKG61	0.0014	Right Sink	JFKG45	<0.0005
Boys Middle Sink	JFKG62	0.0009	Lft Sink-Concession	*** JFKG85	0.0005
Boys Right Sink	JFKG63	0.0009	Rgt Sink-Concession	JFKG86	<0.0005
Girls Rgt Sink	JFKG64	0.0017	District Office	JFKG87	<0.0005
Girls Middle Sink	JFKG65	0.0017	Rm 58 Water Fount	JFKG88	<0.0005
Water Fount.	JFKG66	0.0012	Water Fount-Main Office	JFKG89	<0.0005
Rm 19 Sink	JFKG67	0.0023			
Café. Lft. Sink	JFKG68	0.0018			
Café Middle Sink	JFKG69	0.0016			
Café Rgt Sink	JFKG70	0.0017			
Rm 17 Nurse Sink	JFKG71	0.0014			
Rm 17 Nurse Bath Sink	JFKG72	0.0013			
Quarantine Bathroom	JFKG73	0.0029			
Kit Single Sink	JFKG74	0.0037			
Kit Lft Hand Wash Sink	*** JFKG76	0.0005			
Kit Lft Slop Sink	JFKG77	0.0041			
Kit Middle Slop Sink	JFKG78	0.0027			
Kit Right Slop Sink	JFKG79	0.0031			
Kit Prep Sink	JFKG80 **	0.0216			
Kit Kettle	JFKG81	0.0029			
Kit Steamer	JFKG82	0.0106			
Main Office	JFKG83	<0.0005			
Water Fount.	JFKG1	<0.0005			

*** Break in Numbers

**Over Limit